

Department of Industry and Investment

COAL MINE HEALTH AND SAFETY ACT 2002

COAL MINE HEALTH AND SAFETY REGULATION 2006

Use of electrical plant in a hazardous zone,
not of Gazetted type

Exemption Order No. 317584240001/2

I, ROBERT REGAN, Chief Inspector under the Coal Mine Health and Safety Act 2002 (the Chief Inspector), pursuant to clause 201 of the Coal Mine Health and Safety Regulation 2006 (the Regulation), hereby make the following Order.

Dated this 17th day of December 2010.

ROBERT REGAN,
Chief Inspector
Department of Industry and Investment
(Under delegation from Director-General)

1 Commencement and duration

This Order commences when it is signed by the Chief Inspector and has effect until 1 June 2011 inclusive.

2 Exemption

2.1 Subject to the conditions in clause 3, operators of any underground coal mine are exempt, in respect of plant referred to in clause 2.2 and to the extent indicated by clause 2.3, from the requirements of clause 19 (1) (c) of the Regulation (in relation to the requirement for the use of electrical plant only of a Gazetted type in a hazardous zone).

2.2 The exemption applies in respect of the following plant items:

MDA Ex d 1375 Macey 1100V 55A "A" series bolted coupler; and

MDA Ex d 1285 Macey 1100V 150 / 300 / 425A "B" series bolted coupler,

in accordance with the following plant drawings:

'A' Series Bolted Adaptor drawings:

55-10-AD Issue 2 4-08-07;

55-20-AD Issue 2 4-08-07;

'B' Series Bolted Adaptor drawings:

300-10-AD Issue 2 4-08-07;

300-20-AD Issue 2 4-08-07; and

Cooper Electrical Australia – Assembly Work Instruction 26-07-07 Rev 2

2.3 This exemption permits replacement of a (non-conductive) fibre washer with a copper washer to resolve a potential intermittent conduction path between the plug housing and the internal earth ring, but does not otherwise affect the standing of the approval covered by the applicable Gazetted type. No other alteration to the plant items is permitted.

3 Conditions

3.1 A copy of the drawings and work instruction, detailed in clause 2, and this exemption must be maintained in the plant verification dossier while there is any bolted coupler of a kind identified in that clause in service at the mine concerned.

3.2 Prior to washer replacement the circuit is to be de-energized.

3.3 Prior to re-energisation of the circuit, each replaced earth screw and washer arrangement is to be inspected for deficiencies in ingress protection (IP rating) into the coupler housing and continuity from coupling housing to earth circuit is to be verified.

3.4 A list is to be compiled and maintained of any bolted couplers of a kind identified in clause 2 that are in service at the mine and that have not been upgraded with copper washers.

3.5 A copy of this exemption shall be provided to the site check inspector for the mine.

3.6 A copy of this exemption and the list of non-modified bolted couplers shall be displayed on the Mine Notice Board for the duration of the exemption, while the non-modified bolted couplers are in service at the mine.

FISHERIES MANAGEMENT ACT 1994

Total Allowable Catch for Abalone

I, Steve Whan, Minister for Primary Industries pursuant to section 33 of the Fisheries Management Act 1994, ("the Act") provide notice that the Total Allowable Catch Setting and Review Committee established under section 26 of the Act has, pursuant to section 32 of the Act reviewed the determination titled "Total Allowable Catch for Abalone" published in *Government Gazette* No. 88 of 30 June 2010 at page 3126 and hereby:

1. from midnight on 31 December 2010, revokes pursuant to sections 28 and 33 of the Act the determination titled "Total Allowable Catch for Abalone" dated 30 June 2010; and published in *Government Gazette* No. 88 of 30 June 2010 at page 3126; and
2. determines pursuant to section 28 of the Act and clause 14 of the Fisheries Management (Abalone Share Management Plan) Regulation 2000 ("the Regulation") that the total allowable catch for abalone for the fishing period beginning 1 July 2010 and ending 30 June 2011 (both dates inclusive) is 94 tonnes,

Dated this 21st day of December 2010

STEVE WHAN,
Minister for Primary Industries

FISHERIES MANAGEMENT ACT 1994

Section 8 Notification – Urgent Recreational Fishing Closure Wagonga Inlet

I, PAUL O'CONNOR, Principal Director, Fisheries & Compliance, with the delegated authority of the Minister for Primary Industries and the Director-General of the Department of Industry and Investment pursuant to sections 227 and 228 of the Fisheries Management Act 1994 ("the Act") and pursuant to section 8 of the Act do by this notification prohibit the taking of the species of fish specified in Column 1 of the Schedule below by all recreational fishers, by the methods of fishing specified in Column 2 of the Schedule, from the waters described in Column 3 of the Schedule.